



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. Ampine-A-443-Apex

Status: TERMINATED - September 7, 2023

Manufacturer:

Ampine - a Division of Timber Products Company
11610 Ampine-Fibreform Road
Sutter, CA 95685

Robert T. Page
Technical Director
Information: 209 223 6060

www.timberproducts.com

Product(s):

Apex FR Particle Board

Report:

Product: 0.375" through 1.75" Thick Apex FR Particle Board
Standard Tested to: ASTM E84-15, Standard Method of Test for Surface Burning Characteristics of Building Materials
Guardian Test Report No.: GL 041316; Report Date: 06/03/2016
Test Results: Flame Spread Index = 25; Smoke Developed Index = 10; Class "A" rating

Product: .500" through 1.75" thick Apex FR Particle Board
Standard Tested to: CAN/ULC-S102
Guardian Test Report No.: GL 017817, Report Date 02/09/2017
Test Results: Flame Spread Rating (FSR) = 15; Smoke Developed Calculation (SDC) = 35