



Reliable, responsive,  
and recognized since 1994.

**CORPORATE HEADQUARTERS**

114 Lincoln Ave.  
Cobleskill, NY 12043  
888-680-7974  
www.firetesting.com

**PRODUCT LISTING**

**Reference No.** Ampine-A-443-Apex

**Status:** Current

**Manufacturer:**

Ampine - a Division of Timber Products Company  
11610 Ampine-Fibreform Road  
Sutter, CA 95685

Robert T. Page  
Technical Director  
Information: 209 223 6060

[www.timberproducts.com](http://www.timberproducts.com)

**Product(s):**

Apex FR Particle Board

**Report:**

Product: 0.375" through 1.75" Thick Apex FR Particle Board  
Standard Tested to: ASTM E84-15, Standard Method of Test for Surface Burning Characteristics of Building Materials  
Guardian Test Report No.: GL 041316; Report Date: 06/03/2016  
Test Results: Flame Spread Index = 25; Smoke Developed Index = 10; Class "A" rating

Product: .500" through 1.75" thick Apex FR Particle Board  
Standard Tested to: CAN/ULC-S102  
Guardian Test Report No.: GL 017817, Report Date 02/09/2017  
Test Results: Flame Spread Rating (FSR) = 15; Smoke Developed Calculation (SDC) = 35