



Reliable, responsive,  
and recognized since 1994.

**CORPORATE HEADQUARTERS**

114 Lincoln Ave.  
Cobleskill, NY 12043  
888-680-7974  
www.firetesting.com

**PRODUCT LISTING**

**Reference No.** A-443 - Encore

**Status:** Current

**Manufacturer:**

Ampine - a Division of Timber Products Company  
11610 Ampine-Fibreform Road  
Sutter, CA 95685

**Product(s):**

Encore FR and Ampine FR Particle Board

**Report:**

Product: 0.375" through 1.75" Thick Encore FR and Ampine FR Particle Board  
Standard Tested to: ASTM E84-14, Standard Method of Test for Surface Burning Characteristics of Building Materials;  
Guardian Test Report No.: GL 44315; Report Date: 5/13/15  
Test Results: Flame Spread Index = 25; Smoke Developed Index = 35; Class "A" rating

Product: .500" through 1.75" thick Encore FR and Ampine FR Particle Board  
Standard Tested to: CAN/ULC-S102  
Guardian Test Report No.: GL -17917, Report Date 02/09/2017  
Test Results: Flame Spread Index = 25; Smoke Developed Index = 50