



Reliable, responsive,  
and recognized since 1994.

**CORPORATE HEADQUARTERS**

114 Lincoln Ave.  
Cobleskill, NY 12043  
888-680-7974  
www.firetesting.com

**PRODUCT LISTING**

**Reference No.** ApprovedIndustries-B-1046-Thermocrete

**Status:** Current

**Manufacturer:**

Approved Industries LLC.  
78 Lawrence Street  
Hackensack, NJ 07601

Phone: 201 489 5100

Email: [info@approvedindustries.com](mailto:info@approvedindustries.com)

**Product(s):**

“Thermocrete” Ceramic Flue Liner and Sealant

**Report:**

Guardian Test Report: 104615, Report Date: 12/21/2015

Standards tested to: ULC-S635, Standard for Lining Systems for Existing Masonry or Factory-Built Chimney and Vents: Class 2 Parts A and C, for the venting of oil and gas-fired appliances where the temperature of the flue-gas products does not normally exceed 300°C

See manufacturer’s instructions for application restrictions. “Thermocrete” may only be applied by Approved certified installers.

Approved Industries “Thermocrete” also is a sealant that may be used as a component of a chimney liner system; Guardian Evaluation Report, GL 90811, Report Date: 8/1/2011  
Evaluation Test Standard used is: UL 1777-1996, 8/1/2011, applicable sections (13, 22, 23, 28, 29, 31, Sections 14-21, N/A; 24-27, N/A; 30,

Thermocrete is not evaluated for structural repair or insulating properties.

It may be used to coat an existing code-complying chimney or listed chimney lining system to repair cracks or leaking joints as described in the application instructions.

This product also has been tested to British Standard, EN 1457, Air Leakage, and BS 4207, Refractory Testing.

Thermocrete has received “Approved Material” status for use as an independent chimney lining system for use in chimneys serving gas and oil appliances. This approval is per the following standard: “National Fire Protection Association Standard 211 (2010 edition)”.