GUARDIAN

Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS
114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. DoorWorks-A-951-Door

Status: WITHDRAWN - effective May 5, 2025

Manufacturer:
Door Works of Huntersville
500 Hovis Road
Stanley, NC 28164

Product(s):
"Portsmouth" 20-Minute Panel Door

Report:
Guardian Test Report: GL 95107, Test Date 11/5/2007
Standards Tested To: UL 10B, 20 Minutes without Hose Stream

Guardian Evaluation Report: EER-5-16-19-Z, Evaluation Report Date 5/17/2019
Standards Evaluated To: UL 10C, 20 Minutes Positive Pressure without Hose Stream

1 -3/4" Solid Medium Density Fiberboard "Portsmouth" 20-Minute Panel Door With Inset Flat Panel;
No Less Than 7/8" Thickness At Any Point Inside the Stile and Rail Dimensions