



Reliable, responsive,  
and recognized since 1994.

**CORPORATE HEADQUARTERS**

114 Lincoln Ave.  
Cobleskill, NY 12043  
888-680-7974  
www.firetesting.com

**PRODUCT LISTING**

**Reference No.** RBDillard-A-0160-DuramineMedite

**Status:** TERMINATED - Effective October 31, 2021

**Manufacturer:**

Roseburg, Dillard  
10700 Old Highway 99 South  
Dillard, OR 97432

[www.roseburg.com](http://www.roseburg.com)

Phone: (800) 245-1115

Email: [infor@rfpco.com](mailto:infor@rfpco.com)

**Product(s):**

Duramine® Medite FR MDF”

**Report:**

1/4” through 1-1/4” thick “Duramine® Medite FR MDF”  
Guardian Test Report: GL 015716; Test Report Date: 5/16/2016  
Standards tested to: ASTM E84-15a,  
Results: FSR 25, SDI 10, Rating “A”

1/2” through 1-1/4” thick “Duramine® Medite FR MDF”  
Guardian Test Report: GL 016016; Test Report Date: 6/26/2016  
Standards tested to: CAN/ULC-S102  
Results: FSR 15, SDC 75

Description of Product: Roseburg Duramine® Laminate panels consisting of a paper thermally fused to a substrate of Roseburg Medite FR MDF