



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. RBDillard-A-0160-DuramineMedite

Status: Current

Manufacturer:

Roseburg, Dillard
10700 Old Highway 99 South
Dillard, OR 97432

www.roseburg.com

Phone: (800) 245-1115

Email: infor@rfpco.com

Product(s):

Duramine® Medite FR MDF”

Report:

1/4” through 1-1/4” thick “Duramine® Medite FR MDF”
Guardian Test Report: GL 015716; Test Report Date: 5/16/2016
Standards tested to: ASTM E84-15a,
Results: FSR 25, SDI 10, Rating “A”

1/2” through 1-1/4” thick “Duramine® Medite FR MDF”
Guardian Test Report: GL 016016; Test Report Date: 6/26/2016
Standards tested to: CAN/ULC-S102
Results: FSR 15, SDC 75

Description of Product: Roseburg Duramine® Laminate panels consisting of a paper thermally fused to a substrate of Roseburg Medite FR MDF