



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. RBMedford-A-601-Medite

Status: Current

Manufacturer:

Roseburg, Medford
2685 North Pacific Highway
Medford, OR 97501

Corporate Contact:
Roseburg
PO Box 1088
Roseburg, OR

10599 Old Hwy 99 S
Dillard, OR 97432

Tel: 800 245 1115 (toll free) or
541 679 3311
Fax: 541 679 2543

www.roseburg.com

Product(s):

Arreis MDF

Report:

Arreis MDF is a No-Added Formaldehyde Medium Density Fiberboard

Nominal ¼" and above Arreis MDF (437)

Guardian Test Report # GL-6-2-17-Z, Test Report Date 7/6/2017
Standard Tested To: ASTM E84-16, Surface Burning Characteristics of Building Materials
Rating: "C" Flame Spread Index of 125, Smoke Developed Index of 105