



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. StrekO-A-334-20min

Status: Current

Manufacturer:

Strek-O Doors
518 Birch Street
Abbottsford, WI 54405

www.strekodoors.com

Product(s):

20-Minute Wood Doors: Single Swing, Pairs, Double Egress

Report:

Guardian Evaluation Report: EER 33413-04, Evaluation Report Date: 5/14/2013
Standards Evaluated to: UL 10B, UL 10C, NFPA 80

Guardian Evaluation Report: EER-33413-05, Evaluation Report Date: 5/14/2013
Standards Evaluated to: UL 10B, UL 10C, NFPA 80

Single Swing Doors: up to 5' wide by 12' high, 1-3/4" thick

Pairs: up to 5' wide (each leaf) by 10' high, 1-3/4" thick

Double Egress: up to 5' wide (each leaf) by 10' high, 1-3/4" thick

Cores:

Strek-O Particle Core 20 minute

Strek-O Stave Core 20 minute

Strek-O Structural Composite Lumbar 20 minute

Bonded with hardwood stiles and end rails