



Reliable, responsive,  
and recognized since 1994.

**CORPORATE HEADQUARTERS**

114 Lincoln Ave.  
Cobleskill, NY 12043  
888-680-7974  
www.firetesting.com

**PRODUCT LISTING**

**Reference No.** StrekO-A-334-90min

**Status:** Current

**Manufacturer:**

Strek-O Doors  
518 Birch Street  
Abbottsford, WI 54405

[www.strekodoors.com](http://www.strekodoors.com)

**Product(s):**

90-Minute Mineral Core Doors: Single Swing, Pairs, Double Egress

**Report:**

Guardian Evaluation Report: EER-33413-01, Evaluation Report Date: 5/14/2013  
Standards Evaluated to: UL 10B, UL 10C

Guardian Evaluation Report: EER-33413-02, Evaluation Report Date: 5/14/2013  
Standards Evaluated to: UL 10B, UL 10C

Guardian Evaluation Report: EER-33413-03, Evaluation Report Date: 5/14/2013  
Standards Evaluated to: UL 10B, UL 10C

Guardian Evaluation Report: EER-33413-06, Evaluation Report Date: 5/14/2013  
Standards Evaluated to: NFPA-80 Section 4.4

Single Swing Doors: up to 5' wide by 12' high, 1-3/4" thick

Pairs: up to 4' wide (each leaf) by 9' high, 1-3/4" thick

Double Egress: up to 4' wide (each leaf) by 8' (8' x 8' opening) high, 1-3/4" thick

Core: Skamol Safe Core

Stiles and Rails: 2-ply: Eternite/Etherpan LD 410, 1-1/2" thick Safe Block

Faces: 0.114 thick 2-ply hardwood face with MDF backing

Adhesive: Skamol Super Pro Glue, Dural/IFS G-2360, or equivalent as shown on Guardian approved list

Edge Seal: Graphite-based intumescent dadoed and concealed beneath the hardwood edge of the stiles.  
Intumescent surface applied to the rabbet across the head jamb of the door frame.

Door Frame: single, hollow metal, 16-gauge steel, fully grouted in masonry wall

Lite Openings:

Maximum Lite Openings up to 1296 sq. in. with no dimension exceeding 54 in. unless otherwise tested.

Each individual glazing unit is identified with a label that is visible after installation.

Labeled viewers in doors.

Fire Protection rated glazing materials exceeding 100 sq. in. are not permitted in temperature rise-rated doors