



Reliable, responsive,  
and recognized since 1994.

**CORPORATE HEADQUARTERS**

114 Lincoln Ave.  
Cobleskill, NY 12043  
888-680-7974  
www.firetesting.com

**PRODUCT LISTING**

**Reference No.** USSF-A-035-DualHoseStream120

**Status:** Current

**Manufacturer:**

US Smoke & Fire  
12310 Pinecrest Road, Suite 300  
Reston, VA 20191

**Product(s):**

U. S. Smoke & Fire Dual Hose Stream 120®

**Report:**

Guardian Test Report GL 035517-119; Test Report Date 5/5/2017; Rev 4/11/2018

Standards tested to: UL 10B, Standard for Fire Tests of Door Assemblies  
ASTM E2226, 'Standard Practice for Application of Hose Stream' which meets  
requirements for two-hour wall

Guardian Evaluation Report EER-4-6-18-Z, Evaluation Report Date 4/6/2018

Standards Evaluated to: ASTM E119\*, Standard Test Methods for Fire Tests of Building Construction and Materials  
(this test method is also published under the designation of UL 263\*)

\*Per 2015 IBC section 716.5.5 "Exception: The maximum transmitted temperature rise is not required in buildings equipped throughout with an automated sprinkler system installed in accordance with section 903.3.1.1 or 903.3.1.2"

U. S. Smoke & Fire Dual Hose Stream 120 (for use as a 2-Hour Movable Fire Wall; manufactured to specification as a Fabric Fire & Smoke Shutter System with hose stream that meets two-hour wall requirement\*)