



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. USSmokeFire-A-035-DualHoseStream120

Status: Current

Manufacturer:

US Smoke & Fire
12310 Pinecrest Road, Suite 300
Reston, VA 20191

ussmokeandfirecurtain.com
Phone: 888 917 8777

Product(s):

U. S. Smoke & Fire Dual Hose Stream 120®

Report:

Guardian Test Report GL 035517-119; Test Report Date 5/5/2017; Rev 4/11/2018
Standards tested to: UL 10B, Standard for Fire Tests of Door Assemblies
ASTM E2226, 'Standard Practice for Application of Hose Stream' which meets requirements for two-hour wall

Guardian Evaluation Report EER-4-6-18-Z, Evaluation Report Date 4/6/2018
Standards Evaluated to: ASTM E119*, Standard Test Methods for Fire Tests of Building Construction and Materials
(this test method is also published under the designation of UL 263*)

*Per 2015 IBC section 716.5.5 "Exception: The maximum transmitted temperature rise is not required in buildings equipped throughout with an automated sprinkler system installed in accordance with section 903.3.1.1 or 903.3.1.2"

U. S. Smoke & Fire Dual Hose Stream 120 (for use as a 2-Hour Movable Fire Wall; manufactured to specification as a Fabric Fire & Smoke Shutter System with hose stream that meets two-hour wall requirement*)

http://www.ussmokeandfirecurtain.com/products/Dual-Hose-Stream-120_AE30.html