



Reliable, responsive,  
and recognized since 1994.

**CORPORATE HEADQUARTERS**

114 Lincoln Ave.  
Cobleskill, NY 12043  
888-680-7974  
www.firetesting.com

**PRODUCT LISTING**

**Reference No.** USSmokeFire-A-035-HoseStream120

**Status:** Current

**Manufacturer:**

US Smoke & Fire  
12310 Pinecrest Road, Suite 300  
Reston, VA 20191

ussmokeandfirecurtain.com  
Phone: 888 917 8777

**Product(s):**

U. S. Smoke & Fire Hose Stream 120®

**Report:**

Guardian Test Report GL 035517; Test Report Date 4/18/17; Rev 5/5/17

Standards tested to: UL 10B, Standard for Fire Tests of Door Assemblies  
ASTM E2226, 'Standard Practice for Application of Hose Stream' which meets  
requirements for two-hour wall

U. S. Smoke & Fire Hose Stream 120® for use as a 90 Min. opening protective with hose stream that meets two-hour wall requirement; manufactured to specification

[http://www.ussmokeandfirecurtain.com/products/Hose-Stream-120\\_AE29.html](http://www.ussmokeandfirecurtain.com/products/Hose-Stream-120_AE29.html)