



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. Ventech-B-908-Thermocrete

Status: TERMINATED - Effective 12/14/2018

Manufacturer:

Ventech Industries, Inc.
384 Harold L. Dow Highway, Suite One
Eliot, ME 03903

Product(s):

“Thermocrete” Ceramic Flue Liner and Sealant

Report:

Guardian Test Report: 104615, Test Report Date: 12/21/2015

Standards tested to: ULC-S635, Standard for Lining Systems for Existing Masonry or Factory-Built Chimney and Vents: Class 2 Parts A, for the venting of oil and gas-fired appliances where the temperature of the flue-gas products does not normally exceed 300°C

Guardian Evaluation Report, GL 90811; Test Report Date: 8/1/2011

Evaluation Test Standard used is: UL 1777-1996, 8/1/2011, applicable sections (13, 22, 23, 28, 29, 31, Sections 14-21, N/A; 24-27, N/A; 30,