GUARDIAN

Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS
114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. ASA-A-035517-HoseStream120

Status: Current

Manufacturer:
ASA LLC
4764 Hollins Ferry Road
Halethorpe, MD 21227

Product(s):

Hose Stream 120® Steel-Tex® Fire Shutter

Report:

Guardian Test Report GL 035517; Test Report Date 4/18/17; Rev 5/5/17

Standards tested to: UL 10B, Standard for Fire Tests of Door Assemblies
ASTM E2226, Standard Practice for Application of Hose Stream

Hose Stream 120® Steel-Tex® Fire Shutter attained a fire protective rating of 90 minutes with hose stream.

Reference Documents: 2015 International Building Code (IBC) Table 716.5

2015 IBC Table 716.5 permits a 1-1/2 hour rated fire door and fire assembly to be of a lower rating than the fire resistance rating of the fire barrier in which the assembly is located.

2018, 2021, 2024 IBC, Table 716.1(2)

The Hose Stream 120® Steel-Tex® Fire Shutter meets the minimum fire door and fire shutter assembly (1-1/2 hours) for use in a 2 hour fire wall or fire barrier.

The Hose Stream 120® Steel-Tex® Fire Shutter system is for use in gypsum or masonry wall type constructions and installed in overzied applications up to and including the following dimensions:

For multi-roller use: 984.3 feet in length by 39.4 feet in height

For single-roller use: 19.7 feet in length by 39.4 feet in height