



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. ASAGP-A-035-HS120FirstResponder

Status: Current

Manufacturer:

ASA, GP
4764 Hollins Ferry Road
Halethorpe, MD 21227

Product(s):

Hose Stream 120 First Responder

Report:

Guardian Test Report EER-1-13-21-Z; Test Report Date: June 3, 2021

Standards tested to: UL 10B and ASTM E2226

Hose Stream 120 First Responder attained a fire protective rating of 90 minutes with a hose stream

Reference Documents: 2021 International Building Code (IBC) Table 716.1(2)

The Hose Stream 120 First Responder meets the minimum fire door and fire shutter assembly rating (1-1/2 hours) for use in a 2 hour fire wall or fire barrier