



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. ASAGP-A-035-HoseStream120FirstResponder

Status: Current

Manufacturer:

ASA, GP (US Smoke & Fire)
12310 Pinecrest Road, Suite 300
Reston, VA 20191

ussmokeandfirecurtain.com

Phone: 703 408 4700

Product(s):

U. S. Smoke & Fire Hose Stream 120® First Responder

Report:

Guardian Test Report EER-1-13-21-Z; Test Report Date: June 3, 2021

Standards tested to: UL 10B and ASTM E2226

Reference Documents: 2021 International Building Code (IBC) Table 716.1(2) - The Hose Stream
120 First Responder meets the minimum fire door and fire shutter assembly rating
(1-1/2 hours) for use in a 2 hour fire wall or fire barrier

U. S. Smoke & Fire Hose Stream 120® First Responder attained a fire protective rating of 90
minutes with a hose stream