



Reliable, responsive,  
and recognized since 1994.

**CORPORATE HEADQUARTERS**

114 Lincoln Ave.  
Cobleskill, NY 12043  
888-680-7974  
www.firetesting.com

**PRODUCT LISTING**

**Reference No.** ASAGP-A-035-SD60

**Status:** Current

**Manufacturer:**

ASA, GP  
4764 Hollins Ferry Road  
Halethorpe, MD 21227

**Product(s):**

SD60 Smoke Curtain; SD60 Deployable Draft Curtain

**Report:**

Guardian Test Report EER-5-28-21-Z; Test Report Date: July 16, 2021

Standards tested to: UL 10B

The SD60 Smoke Curtain, SD60 Deployable Draft Curtain meets the fire protective rating of 20 minutes with no hose stream

Reference Documents: NFPA 252