



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. ASAGP-A-035-SD60

Status: Current

Manufacturer:

ASA, GP
12310 Pinecrest Road, Suite 300
Reston, VA 20191

Product(s):

SD60® Smoke Curtain; SD60® Deployable Draft Curtain

Report:

Guardian Test Report EER-5-28-21-Z; Test Report Date: July 16, 2021

Standards tested to: UL 10B

The SD60® Smoke Curtain, SD60® Deployable Draft Curtain meets the fire protective rating of 20 minutes with no hose stream

Reference Documents: NFPA 252