



Reliable, responsive,  
and recognized since 1994.

**CORPORATE HEADQUARTERS**

114 Lincoln Ave.  
Cobleskill, NY 12043  
888-680-7974  
www.firetesting.com

**PRODUCT LISTING**

**Reference No.** ASAGP-A-11321Z-HS120FirstResponder

**Status:** Current

**Manufacturer:**

ASA, GP  
4764 Hollins Ferry Road  
Halethorpe, MD 21227

**Product(s):**

Hose Stream 120 First Responder

**Report:**

Guardian Test Report EER-1-13-21-Z; Test Report Date: June 3, 2021

Standards tested to: UL 10B and ASTM E2226

Hose Stream 120 First Responder attained a fire protective rating of 90 minutes with a hose stream

Reference Documents: 2021 International Building Code (IBC) Table 716.1(2)

The Hose Stream 120 First Responder meets the minimum fire door and fire shutter assembly rating (1-1/2 hours) for use in a 2 hour fire wall or fire barrier