



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. ASAGP-A-035-HoseStream120

Status: Current

Manufacturer:

ASA, GP
4764 Hollins Ferry Road
Halethorpe, MD 21227

Product(s):

Hose Stream 120 Fire Shutter System

Report:

Guardian Test Report GL 035517; Test Report Date 4/18/17; Rev 5/5/17

Standards tested to: UL 10B, Standard for Fire Tests of Door Assemblies
ASTM E2226, 'Standard Practice for Application of Hose Stream'

Hose Stream 120 attained a fire protective rating of 90 minutes with hose stream

Reference Documents: 2015 International Building Code (IBC) Table 716.5

The Hose Stream 120 Fire Shutter System meets the minimum fire door and fire assembly rating (1-1/2 hours) for use in a 2 hour wall assembly rating