



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. ASAGP-A-035517119-DualHoseStream120

Status: Current

Manufacturer:

ASA, GP
4764 Hollins Ferry Road
Halethorpe, MD 21227

Product(s):

Dual Hose Stream 120 Fire Shutter System

Report:

Guardian Test Report GL 035517-119; Test Report Date 5/5/2017; Rev 4/11/2018

Standards tested to: UL 10B, Standard for Fire Tests of Door Assemblies
ASTM E2226, 'Standard Practice for Application of Hose Stream' which meets
requirements for two-hour wall

Guardian Evaluation Report EER-4-6-18-Z, Evaluation Report Date 4/6/2018

Standards Evaluated to: ASTM E119*, Standard Test Methods for Fire Tests of Building Construction and Materials
(this test method is also published under the designation of UL 263*)

*Per 2015 IBC section 716.5.5 "Exception: The maximum transmitted temperature rise is not required in buildings equipped throughout with an automated sprinkler system installed in accordance with section 903.3.1.1 or 903.3.1.2"

Dual Hose Stream 120 for use as a 2-Hour Movable Fire Wall; manufactured to specification as a Fabric Fire & Smoke Shutter System with hose stream that meets two-hour wall requirement*