



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. ASAGP-A-9921Z2-HS180FirstResponder

Status: Current

Manufacturer:

ASA, GP
4764 Hollins Ferry Road
Halethorpe, MD 21227

Product(s):

Hose Stream 180 First Responder

Report:

Guardian Test Report EER-9-9-21-Z-2; Test Report Date: January 19, 2022

Standards tested to: UL 10B

Hose Stream 180 First Responder attained a fire protective rating of 180 minutes with a hose stream.

Reference Documents: ASTM E2226

2021 International Building Code (IBC) Table 716.1(2)

The Hose Stream 180 First Responder meets the minimum fire door and fire shutter assembly rating (3 hours) for use in a 3 hour fire wall or fire barrier