GUARDIAN

Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS
114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. ASA-A-121621Z-HS120HorizontalSR

Status: Current

Manufacturer:
ASA LLC
4764 Hollins Ferry Road
Halethorpe, MD 21227

Product(s):

Hose Stream 120® Horizontal Sliding Retract (SR) Fire Shutter

Report:

Guardian Test Report EER-12-16-21-Z; Test Report Date: February 7, 2022

Standards tested to: UL 10B, Standard for Fire Tests of Door Assemblies
ASTM E2226, Standard Practice for Application of Hose Stream

Hose Stream 120® Horizontal Sliding Retract (SR) Fire Shutter attained a fire protective rating of 120 minutes with hose stream.

The Hose Stream 120® Horizontal Sliding Retract (SR) Fire Shutter system is for use in gypsum or masonry type wall construction in floor pocket or wall pocket and installed in single- and multi-roller applications up to and including the following dimensions:

Single sliding curtain up to 42'-10" by 42'-10" side to side travel in x/y/z axis

Bi-parting sliding curtain up to 85'-8" side to side travel in x/y/z axis

Model with sliding retraction marked (SR) with egress option.

The above mentioned product meets the minimum 2-hour rolling fire door or rolling fire barrier assembly rating for use in enclosed gypsum, masonry walls, and floor openings. Wall and floor headbox pocket dimensions based on travel distance.