



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. ASAGP-A-121621Z-HS120Horizontal

Status: Current

Manufacturer:

ASA, GP
4764 Hollins Ferry Road
Halethorpe, MD 21227

Product(s):

Hose Stream 120 Horizontal Fire Shutter

Report:

Guardian Test Report EER-12-16-21-Z; Test Report Date: February 7, 2022

Standards tested to: UL 10B

Hose Stream 120 Horizontal Fire Shutter attained a fire protective rating of 120 minutes with a hose stream.

Reference Documents: ASTM E2226