



Reliable, responsive,  
and recognized since 1994.

**CORPORATE HEADQUARTERS**

114 Lincoln Ave.  
Cobleskill, NY 12043  
888-680-7974  
www.firetesting.com

**PRODUCT LISTING**

**Reference No.** DoorSystems-A-42523Z-DSIHS10B180

**Status:** Current

**Distributor:**

Door Systems  
1150 Las Brisas  
Placentia, CA 92870

**Product(s):**

DSI-HS10B Hose Stream 180 Rated Smoke and Fire Shutter

**Report:**

Guardian Test Report EER-4-25-23-Z; Test Report Date: September 25, 2023

Standards tested to: UL 10B, Standard for Fire Test of Door Assemblies  
ASTM E2226, Standard Practice for Application of Hose Stream

Reference Documents: 2021 International Building Code (IBC) Table 716.1(2)

Model below is for use in gypsum or masonry wall type constructions, maximum 144in wide by 120in high. When greater than 144in wide by 120in high, the single barrel and multi-barrel assemblies are eligible for an Oversized label and may be produced up to 19.7ft wide by 39.4ft high for the single barrel assemblies, and up to 984.3ft wide by 39.4ft high for the multi-barrel assemblies. Model below may have a suffix (E) for egress option.

Model DSI-HS10B(E) Hose Stream 180 Rated Smoke and Fire Shutter, 180 minute fire rating with hose stream. This product meets the minimum fire door and fire assembly rating for use in a 3 hour wall or fire barrier assembly.