



Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS

114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. DoorSystems-A-83123Z-DSIHHS10B

Status: Current

Distributor:

Door Systems
1150 Las Brisas
Placentia, CA 92870

Product(s):

DSI-HHS10B Hose Stream Rated Horizontal Fire Curtain

Report:

Guardian Test Report EER-8-31-23-Z; Test Report Date: September 25, 2023

Standards tested to: UL 10B, Standard for Fire Test of Door Assemblies
ASTM E2226, Standard Practice for Application of Hose Stream

Model below is for use in gypsum or masonry wall type constructions, maximum 10'-9" wide by 11'-5" travel. When greater than 10'-9" wide by 11'-5" travel, an Oversized Label may be produced up to 32'-10" wide by 32'-10" travel for single parting curtains and up to 65'-8" travel for bi-parting curtains.

Model DSI-HHS10B Hose Stream Rated Horizontal Fire Curtain, 120-minute fire rating with hose stream. This product meets the minimum 2-hour fire door or fire barrier assembly rating for use in horizontal openings.