GUARDIAN

Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS
114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. Kronospan-A-051225-FirewallFR

Status: Current

Manufacturer:
Kronospan LaGrande LLC
62621 OR Hwy 82
LaGrande, OR 97850

Product(s):

FirewallFR® Particleboard, 3/8 inch through 1-1/8 inch

Report(s):

ASTM E-84

3/8" up to 3/4" FirewallFR® Particleboard (MUF resin) with revised APP of 12% face and 4% core
Guardian Test Report: EER-12-19-17-W; Test Report Date: 2/6/2018
Standard tested to is: ASTM E84-17, Surface Burning Characteristics of Building Materials
Results: Rating "A", Flame Spread Index of 25, Smoke Developed Index of 130

3/4" through 1-1/8" FirewallFR® Particleboard (MUF resin) with revised APP of 11% face and 2% core
Guardian Test Report: EER-10-2-17-Z-2; Test Report Date: 10/23/2017
Standard tested to is: ASTM E84-17, Surface Burning Characteristics of Building Materials
Results: Rating "A", Flame Spread Index of 25, Smoke Developed Index of 55

CAN/ULC-S102

3/8" up to 3/4" FirewallFR® Particleboard with MUF Resin APP Face and Core
Guardian Test Report: EER-7-19-18-Y; Test Report Date: 9/3/2018
Standard tested to is: CAN/ULC-S102, Surface Burning Characteristics of Building Materials and Assemblies
Results: Rounded 3-Test Average Flame Spread Rating (FSR) is 25, Smoke Developed Calculation (SDC) is 65

3/4" through 1-1/8" FirewallFR® Particleboard with MUF Resin APP Face and Core
Guardian Test Report: EER-7-19-18-Z; Test Report Date: 9/3/2018
Standard tested to is: CAN/ULC-S102, Surface Burning Characteristics of Building Materials and Assemblies
Results: Rounded 3-Test Average Flame Spread Rating (FSR) is 20, Smoke Developed Calculation (SDC) is 25