GUARDIAN

Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS
114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. ASA-A-52821Z-SD60

Status: Current

Manufacturer:
ASA LLC
4764 Hollins Ferry Road
Halethorpe, MD 21227

Product(s):

SD60® Smoke Curtain

Report:

Guardian Test Report EER-5-28-21-Z; Test Report Date: July 16, 2021

Standard tested to: UL 10B

The SD60® Smoke Curtain meets the fire protective rating of 20 minutes with no hose stream.

Reference Document: NFPA 252