GUARDIAN

Reliable, responsive,
and recognized since 1994.

**CORPORATE HEADQUARTERS**
114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

# PRODUCT LISTING

**Reference No.** KentSFC-A-111924Z-AFC07SMINSUL119

**Status:** Current

**Manufacturer:**
Kent Smoke and Fire Curtains
Unit 10, 7th Street, Al Qusais Industrial Area 2
PO Box 233962, Dubai, UAE

**Product(s):**

AFC07S/M-INSUL-119 Deployable Fabric Fire Wall

**Report:**

Guardian Test Report EER-11-19-24-Z; Test Report Date: February 3, 2025

Standard tested to: ASTM E119 with Hose Stream; UL 263-22; ASTM E2226-23a; CAN/ULC-S101-21

Model below is for use in gypsum or masonry wall type constructions, maximum 144 in wide by 120 in high. When greater than 144 in wide by 120 in high, the single barrel and multibarrel assemblies are eligible for the Oversize Label and may be produced up to 19.7 ft wide by 39.4 ft high for single barrel assemblies and up to 984.3 ft wide by 39.4 ft high for multibarrel assemblies respectively. For use in vertical wall applications or horizontal floor opening applications. Model below may have a suffix (E) for egress option.

Model AFC07S/M-INSUL-119 Deployable Fabric Wall, 2-hour fire rating with hose stream. This product meets the minimum 2-hour fire wall or fire barrier assembly requirement in accordance with ASTM E119 (UL 263) requirements as a deployable fire wall with a temperature rise rating 250-degree Fahrenheit at 120 minutes.