GUARDIAN

Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS
114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. KentSFC-A-4224Z-AFC04SM690SSHSM

Status: Current

Manufacturer:
Kent Smoke and Fire Curtains
Unit 10, 7th Street, Al Qusais Industrial Area 2
PO Box 233962, Dubai, UAE

Product(s):

AFC04S/M-690SS HS Manual Smoke and Fire Shutter

Report:

Guardian Test Report: GR-4-2-24-Z; Test Report Date: August 15, 2024

Standards tested to: UL 10B, Standard for Fire Test of Door Assemblies
ASTM E2226, Standard Practice for Application of Hose Stream

Post-test Evaluation for Compliance to CAN/ULC-S104, Standard Method for Fire Tests of Door Assemblies

Reference Documents: 2021 International Building Code (IBC) Table 716.1(2)

Model below is for use in gypsum or masonry wall type constructions, maximum 144in wide by 120in high. When greater than 144in wide by 120in high, the single barrel and multi-barrel assemblies are eligible for an Oversized Label and may be produced up to 19.7ft wide by 39.4ft high for the single barrel assemblies, and up to 984.3ft wide by 39.4ft high for the multi-barrel assemblies.

Model AFC04S/M-690SS HS Manual Smoke and Fire Shutter, 180 minute fire rating with hose stream. This product meets the minimum fire door and fire assembly rating for use in a 3 hour wall or fire barrier assembly.