GUARDIAN

Reliable, responsive,
and recognized since 1994.

CORPORATE HEADQUARTERS
114 Lincoln Ave.
Cobleskill, NY 12043
888-680-7974
www.firetesting.com

PRODUCT LISTING

Reference No. KentSFC-A-83123Z-AFC04SM690SSHSH

Status: Current

Manufacturer:
Kent Smoke and Fire Curtains
Unit 10, 7th Street, Al Qusais Industrial Area 2
PO Box 233962, Dubai, UAE

Product(s):

AFC04S/M-690SS HS Horizontal Fire Curtain

Report:

Guardian Test Report EER-8-31-23-Z; Test Report Date: September 25, 2023

Standards tested to: UL 10B, Standard for Fire Test of Door Assemblies
ASTM E2226, Standard Practice for Application of Hose Stream

Post-test Evaluation for Compliance to CAN/ULC-S101, Standard Methods of Fire Endurance Tests of Building Construction and Materials

Post-test Evaluation for Compliance to NFPA 252, Standard Methods of Fire Tests of Door Assemblies, for an assigned fire protection rating of 90 minutes.

Model below is for use in gypsum or masonry wall type constructions, maximum 10′-9″ wide by 11′-5″ travel. When greater than 10′-9″ wide by 11′-5″ travel, an Oversized Label may be produced up to 32′-10″ wide by 32′-10″ travel for single parting curtains and up to 65′-8″ travel for bi-parting curtains.

Model AFC04S/M-690SS HS Horizontal Fire Curtain, 120-minute fire rating with hose stream (UL 10B only). This product meets the minimum 2-hour fire door or fire barrier assembly rating for use in horizontal openings.